

4 STATE ROAD - WASTE WATER

DRAFT - 4 State Road - Proposed Mixed Use Development

Bedrooms Proposed	Gallons Per Bedroom	Total
22	110	2,420

Retail SF	Gallons Per 1000 SF	Total
3,156	50	158

Office Space SF	Gallons Per 1000 SF	Total
3,156	75	237

Total Gallons	
Bedroom	2,420
Retail	158
Total	2,578
Office (Difference)	79
Existing In Ground / Betterment Town Sewer Paid	652
Request to Tisbury Wastewater	
Connect existing flow per betterment	652
Request additional flow per above	1,926