

Asbestos Identification Laboratory

165 New Boston St., Ste 227
Woburn, MA 01801
781-932-9600

Web: www.asbestosidentificationlab.com
Email: mikemanning@asbestosidentificationlab.com

Batch: 38275

PAT Programs
AIHA Proficiency
Analytical Testing Programs
Lab ID: 200379

December 17, 2018

Ed Morgan
Asbestos Consultants
61 Unity Avenue
Belmont, MA 02478

Project Number:

Project Name: 3 Uncas Rd., Vineyard Haven

Date Sampled: 2018-12-17
Work Received: 2018-12-17
Work Analyzed: 2018-12-17

Analysis Method: PCM NIOSH 7400

Dear Ed Morgan,

Asbestos Identification Laboratory has completed the analysis of the samples from your office for the above referenced project .

The information and analysis contained in this report have been generated using Phase Contrast Microscopy (PCM), NIOSH 7400 method, revision #3. Asbestos Identification Laboratory participates in the AIHA PAT Program for asbestos fiber counting; Laboratory ID # 200379. Limit of detection is 7 fibers/mm².

Laboratory results represent the analysis of samples as submitted by the customer. Information regarding sample location, description, area, volume, etc., was provided by the customer. Asbestos Identification Laboratory is not responsible for sample collection activities or analytical method limitations. Unless notified in writing to return samples, Asbestos Identification Laboratory discards customer samples after 30 days. Samples containing subsamples or layers will be analyzed separately when applicable. Reports are kept at Asbestos Identification Laboratory for three years. This report shall not be reproduced, except in full, without the written consent of Asbestos Identification Laboratory.

- NVLAP Lab Code: 200919-0
- Massachusetts Certification License: AA000208
- State of Connecticut, Department of Public Health Approved Environmental Laboratory Registration Number: PH-0142
- State of Maine, Department of Environmental Protection Asbestos Analytical Laboratory License Number: LB-0078(Bulk) LA-0087(Air)
- State of Rhode Island and Providence Plantations. Department of Health Certification: AAL-121
- State of Vermont, Department of Health Environmental Health License AL934461

Thank you Ed Morgan for your business.

Michael Manning
Owner/Director

December 17, 2018

Ed Morgan
Asbestos Consultants
61 Unity Avenue
Belmont, MA 02478

Project Number:

Project Name: 3 Uncas Rd., Vineyard Haven

Date Sampled: 2018-12-17

Work Received: 2018-12-17


Work Analyzed: 2018-12-17

Analysis Method: PCM NIOSH 7400

FieldID LabID	Location / Additional Information	Volume (Liters)	Fibers / 100 Fields	Fibers / CC
1	Kitchen/Living Room	1200	0.0	BDL < 0.002
25221				

Monday 17 December

Analyzed by:



End of Report

Batch: 38275

Page 1 of 1

3



165 New Boston Street, Suite 227
Woburn, MA 01801
www.asbestosidentificationlab.com
781-932-9600

LESS THAN 3 HRS (✓)
SAME DAY ()
NEXT DAY ()
TWO DAY ()

Asbestos Air Sample Field Data Sheet

Date: 12-17-18
Batch #: 38275
Client: Airista Consultants

of Samples Received _____
Project: 3 Uncas Rd - Vineyard Haven

AIL Lab # Client I.D. #	Start Flow (l/m) End	Start Time End	Total Minutes	Total Volume (Liters)	Total Fibers/ Field	Concentration (f/cc)	Location / Additional Data	Type of Sample
<u>1</u> <u>25221</u>	<u>15:0</u> <u>15:0</u>	<u>14:20</u> <u>15:40</u>	<u>80</u>	<u>1200</u>	<u>0/100</u>	<u>BDL</u>	<u>Kitchen/living rm</u>	<input checked="" type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other
								<input type="checkbox"/> Clearance <input type="checkbox"/> Background <input type="checkbox"/> Other

NIOSH Method 7400 (A) Sampling Tech: _____ Date Analyzed: 12/17/18
Phase Contrast Microscopy Analyst: [Signature]

Air Sample Chain of Custody	Relinquished by: <u>SEM</u> Date: <u>12/30</u>	Relinquished by: _____ Date: _____
	Received by: _____ Date: <u>12/17/18</u>	Received by: <u>[Signature]</u> Date: <u>12/17/18</u>

Additional Notes: The post abatement clearance level for reoccupancy is 0.010 F/CC