

Shearer numbers

Sheri Caseau

Fri 12/10/2021 9:03 AM

To: Alex Elvin <elvin@mvcommission.org>;

Cc: Adam Turner <turner@mvcommission.org>;

As they propose 15 bedrooms at 12mg/l for 244 days will work

Below are the calculations for 365 days and 244 days for the 8 and 12 mg/l systems

Load for property $.751 * 11.83 = 8.88$ kg/yr

bedrooms	# days	l/A mg/l	N load	roof runoff	lawn	total N(kg/yr)
15	244	12	5.55	0.52	1.95	8.02
15	365	12	8.3	0.52	1.95	10.77
15	365	8	5.53	0.52	1.95	8

Sheri L. Caseau
Water Resource Planner
Martha's Vineyard Commission
caseau@mvcommission.org