

Fwd: 7 Arlington

william sullivan <chuck@sullivanassociatesarchitects.com>

Tue 3/29/2022 1:18 PM

To: Alex Elvin <elvin@mvcommission.org>;

Alex,

FYI below from the contractor at 7 Arlington Ave.
Thank you,

Chuck Sullivan
Principal | Architect

sullivan + associates architects
52 narragansett avenue | po box 989 | oak bluffs, ma 02557
office 508.693.0500 x2
mobile 617.347.8600
sullivanassociatesarchitects.com

----- Forwarded message -----

From: **Bill Potter** <bells@vineyard.net>
Date: Tue, Mar 29, 2022 at 12:44 PM
Subject: 7 Arlington
To: <chuck@sullivanassociatesarchitects.com>, Eunu Chun <eunuchun@gmail.com>

To whom it may concern

My company, Squash Meadow Construction, has done multiple projects at 7 Arlington Ave over the last 10+ years. More recently, we replaced some deck boards and painted the deck. In the course of this work, we discovered much of the structural components or the deck have rotted. Attached/below are some pictures. Based on my observations, the entire deck and roof need to be rebuilt from scratch. I would also assume that much of the structural timbers for the house are in the same condition.

Sincerely,
Bill Potter
President
Squash Meadow Construciton, Inc
508 693 7451
www.squashmeadow.com



Example of one of the posts that has rotted.